



## NSW SWIMMING POOL REGISTER

### Pool 'self assessment' checklist

#### Indoor Pools

	Does your pool meet the safety standards?	
<b>Window restrictions for indoor pools</b>		
The windows can only open to a maximum of 100mm	Yes	No
<b>OR</b> The windows are totally covered by bars or a mesh screen	Yes	No
<b>OR</b> The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the ground	Yes	No
<b>Doors that have access to pools</b>		
There is a latch on the door at least 1500mm above floor level	Yes	No
Doors open away from the pool area and are self-latching	Yes	No
There are no pet doors or openings greater than 100mm	Yes	No
<b>Wall restrictions for indoor pools</b>		
There are no wall openings greater than 100mm	Yes	No
<b>Around the pool</b>		
There is an appropriate warning sign, including details of resuscitation (CPR) techniques, in the immediate vicinity of the pool area which can be easily read from a distance of 3 metres.	Yes	No

*If you have answered 'No' to any of the questions above, please contact your local council for further information.*