



## NSW SWIMMING POOL REGISTER

### Pool 'self assessment' checklist

#### Swimming Pools on a small property 230 square metres or less

*Prior to 1 July 2010, Property owners had the choice of either fencing their pools, or having latchable doors and restricted window openings as their pool barrier.*

Swimming Pools built/installed with door and window as barrier before 1 July 2010 (Including requirements for indoor pool and spa pool)		
Requirements	Does your pool meet the safety standards?	
<b>Doors:</b>		
There is a latch on the door at least 1500mm above floor level on every door entering the pool area	Yes	No
Doors open away from the pool area and are self-latching	Yes	No
There are no pet doors or openings to the pool area greater than 100mm	Yes	No
<b>Windows:</b>		
The windows can only open to a maximum of 100mm	Yes	No
<b>OR</b> The windows are totally covered by bars or a mesh screen	Yes	No
<b>OR</b> The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor	Yes	No
<b>Wall restrictions</b>		
There are no wall openings greater than 100mm	Yes	No
<b>Around the pool</b>		
There is an appropriate warning sign, including details of resuscitation (CPR) techniques, in the immediate vicinity of the pool area which can be easily read from a distance of 3 metres.	Yes	No
<b>Spa</b>		
The spa is covered by a child-resistant lockable lid	Yes	No

*If you have answered 'No' to any of the questions above, please contact your local council for further information.*